

**SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:

# Vietnam Hengli New Materials Co., Ltd.

Lot N(N-1), Quang Chau IP, Quang Chau Commun, Viet Yen District, Bac Giang, VietNam

For the following product(s):

## Luxury Vinyl Tile:

Engineered Vinyl, Engineered Vinyl with Cork, Rigid LVT/SPC/SRB, Solid Vinyl, Solid Vinyl with Cork, SPC with Cork, Engineered LVT with MgO Core, SPC with & without pad options (Cork, IXPE or EVA padding) (Maximum thickness: 9.5mm),  
Light SPC with & without pad options (Cork, IXPE, EVA), WPC with and without pad options (Cork, or IXPE) (Maximum Thickness: 15.0mm)

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## FloorScore®

Indoor Air Quality Certified to SCS-105 v4.2-2023

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-20068

Valid from: June 01, 2024 to May 31, 2025

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink.

Nicole Munoz, Vice President, ECS  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA